

**Peacham Pond Boat Launch
Onion Point Road
Peacham, Vermont**

REQUEST FOR BIDS – ADDENDUM 1

July 25, 2024

Clarifications and responses to Contractor questions asked during the mandatory site visit (held on July 23, 2024) are provided below in **bold**.

1. Will the contractor be responsible for moving the kiosk? **Yes, the contractor will be responsible for moving the kiosk. The final location will be determined in the field between F&W and the engineer.**
2. Clarification on the depth of Type 1 stone? **All areas calling for Type I Stone fill (swale and spillways) shall be installed at a depth of 12”.**
3. What is the notice period for closing the ramp? **F&W has requested a minimum of 14-day notice (30 days preferred) prior to the ramp closure and construction. In addition, F&W has requested signage be installed by the contractor near the top of the ramp to catch people’s attention and inform them of the upcoming closure / construction.**
4. What is the concrete footer found near the sign on the side of the ramp? **F&W was unaware of this infrastructure. The contractor will be responsible for exploratory digging and removal of the concrete. It is assumed that this was a previous kiosk footer.**